

Compliance Statement

Screened Category 5⁺ (Cat. 5e) ISO/IEC, EN & TIA/EIA Communication Cable

Madex Identification FTP 4PR AWG 24 Cat. 5e

Category 5⁺, Overall Foil Screened 100 **W**, 4 Twisted Pairs, 24 AWG, Flame Retardant, Copper Cable

Fabryka Kabli Madex Stefanówka 4B 05-462 Wiązowna, Poland

Compliance Statement No. 100301D

This Screened ISO/IEC, EN & TIA/EIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 5:2002 performance requirements of 2nd edition ISO/IEC Generic Cabling Standard 11801 and CENELEC Generic Cabling Standard EN 50173-1, the Category 5e requirements of ANSI/TIA/EIA Generic Cabling Standard 568-B.2 and IEC Cable Standard 61156-5, and the requirements of 2nd edition CENELEC Cable Standard EN 50288-2-1. Flame Retardancy is verified according to IEC 60332-1. The cable has EMC Performance Rating 7. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 months intervals.

Hoersholm, 10 October 2003

Ole houlton

Ole Lambertsen Test Responsible Hoersholm, 10 October 2003

Poul Villien

Coordinating Manager