



# Compliance Statement

## Unscreened Category 5<sup>+</sup> (Cat. 5e) ISO/IEC, EN & TIA/EIA Communication Cable

**Madex Identification UTP 4PR AWG 24 Cat. 5e**  
Category 5<sup>+</sup>, Unscreened  
100 W, 4 Twisted Pairs, 24 AWG, Flame Retardant, Copper Cable

**Fabryka Kabli Madex**  
**Stefanówka 4B**  
**05-462 Wiązowna, Poland**

*Compliance Statement No. 99224F*

*This Unscreened ISO/IEC, EN & TIA/EIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 5:2002 performance requirements of 2nd edition ISO/IEC Generic Cabling Standard 11801 and CENELEC Generic Cabling Standard EN 50173-1, the Category 5e requirements of ANSI/TIA/EIA Generic Cabling Standard 568-B.2 and IEC Cable Standard 61156-5, and the requirements of 2nd edition CENELEC Cable Standard EN 50288-3-1. Flame Retardancy is verified according to IEC 60332-1. The cable has EMC Performance Rating 5. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 months intervals.*

Hoersholm, 10 October 2003

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

Hoersholm, 10 October 2003

*Paul Villien*

Poul Villien  
Coordinating Manager